

Road Water Sewer Report

April 19th 2012

Roads: Road maintenance issues were discussed with Dennis Jameson on 4-10-12.

He will move forward on getting the culverts finished up near the end of the county road, and identify and repair areas that need to be patched. Some of this work needs to be coordinated with water service repairs. (See below)
.Culverts have been purchased and installed, backfill is pending Equipment rental.

Water: We met with Engineer Bill Quisnell on 3-28-12 at his office in Truckee and agreed to use his services to assist us in getting the water treatment plant functioning properly.

Turbidity is an ongoing issue. It was decided that samples from the spring should be taken for comparison to preplant samples; this was done on 4-15-12 by Mike Smith. Results have not been returned at this time. All other required samples have been done as scheduled.

We are not filtering the water at this time (due to high turbidity). The county has directed us to maintain a 1.0 residual level of chlorine leaving the plant. This is being done. The boil order is still in effect.

Replacement of valves at the top of Spruce Street is scheduled. Dennis Jameson intends to hire a pipe locator to mark services and manholes and begin saw cutting next week.

Sewer: The issue of the portion of our system that is original was discussed with Dennis Jameson. An analysis of costs and procedure and other sewer issues will be forthcoming.

Schoolhouse: An email from John Parker indicated that he is ready to move forward on the painting of the building. He asked if an accent trim color is desired, I told him to suggest some sample colors for review.
Repair of the foundation and replacement of the entry deck needs to be put out to bid for a cost breakdown.

Power meters were read and recorded as scheduled.