

July 19th 2012
Road Water Sewer Report

Roads: No issues with the roads were reported.

Water: Samples were submitted and returned as scheduled. High turbidity is clogging the Harmsco filter, water from the spring is going directly to the tank. Chlorine is added manually. The boil order remains in effect. We met with John Mendele from California Rural Water. He will help us pursue grant money to help with the cost of future plant expenses. When asked if grant monies can be applied retroactively, John stated that it is very difficult to do so and advised that we be careful in spending money until we have it. Paul Rose submitted the pre-application forms to the agency. This is a lengthy process.

It was suggested that a pipe locator and a GPS be used to walk the spring line and plot its location on a topographic map and to look for evidence of leaks. Cal Rural will try to make a pipe locator available; Mike Smith has access to a GPS unit.

Acumen Engineering has begun diagramming our system and taken steps to design the correct pre-filter backwash system.

The meeting with the County is set for July 25th. AT 11:30 A.M.

Sewer: Samples were taken as scheduled. The Quarterly reports were compiled and sent as required. No other issues were reported.

Power meter readings were taken and recorded as scheduled.

Chuck Grooms

Submitted by Chuck Grooms; Roads, Water, Sewer Commissioner FPOA