

## Sept 14, 2013 Road Water Sewer Report

Roads: No issues with the roads have been reported, however there are areas that need to be patched and/or repaired. I spoke with Jess Bailey and informed him that we need to deal with this issue in October.

### Water:

Water samples have been submitted as scheduled.

A residual chlorine level is being maintained to county specifications.

The boil order remains in effect until such time as the plant is operating as designed.

Service lines and valves are scheduled to be replaced. Jess and Dennis are aware that this is a budget approved item and that work can proceed.

We are currently seeing the yellow flag meaning we are not exceeding our spring production.

The spring is currently providing about 16 gallons per minute; use is about 30 gallons per minute.

A meeting with Paul, Mike Pete Catherine and Cal Rural Water took place; notes from that meeting are being compiled. Mike said that the settling tank and expansion of the existing tank for more storage were mentioned and that this is a direction that should be considered. This would require an additional pump to return the water to the tank in addition to the backwash filter. The discharge from the backwash process must be returned to our septic system, we need to determine how much volume we are talking about and whether that will have any impact on that system.

Sewer: Samples have been taken as scheduled. The clean outs near the railroad tracks need to be replaced/repared and permanently marked to prevent future damage.

### Schoolhouse:

Power meters were read and recorded as scheduled monthly as required.

Chuck Grooms, RWS