

## Roads, Water and Sewer Report - February 11, 2014

### Roads, Water and Sewer Report

Roads: There were no issues reported with the roads. There are several areas that need attention .

Snowplow service has been adequate.

Water: Water Samples have been taken and tested as scheduled.  
The boil order remains in effect.

Our spring production is below normal for this time of year. The production rate is 15 gpm. Normally it would be 30 gpm. If below average precipitation persists extreme shortages could occur in the warmer months.

Sewer: Samples were taken and tested as scheduled.  
No issues were reported.

Quarterly reports for 2013 were compiled and submitted to the Regional Water Quality Control

Power meters were read, recorded and forwarded .

Submitted by C Grooms  
Roads, Water and Sewer Commissioner  
Citizen Volunteer