

July 20, 2014

## Roads Water and Sewer Report

### Roads:

No issues with the roads were reported.

### Water:

Spring flow is averaging 10 gpm. The Drought Contingency Plan was posted. We have had the red flag displayed as conditions warrant. Town response has been good and we were able to go back to yellow. Afternoon thunder showers have helped reduce consumption.

Under Acumen Engineering's direction, a modification to the tank's pressure valve was made (on Saturday, July 19, by Mike and Paul) to control the amount of air in our system.

Samples have been taken and tested as required.

The boil order remains in effect.

### Sewer:

No issues with the sewer were reported.

Samples have been taken and tested as required.

Power meters were read, recorded and forwarded.

Submitted by Chuck Grooms,  
RWS FPOA