

August 20, 2014

Roads Water and Sewer Report

Roads:

I spoke with Dennis Jamason and directed him to check storm drains and culverts

Water:

Our current spring flow is 5-7 gpm. The tank level is 6-1/2 feet. The red flag has been displayed since Sunday, the 17th, and most likely we will go to a black flag this evening.

Mike will pick up a pallet of 2.5 gallon containers for emergency drinking water use.

Samples have been taken and tested as required.

The boil order remains in effect.

Sewer:

Samples have been taken and tested as required.

A roof leak was discovered at the utility building. I authorized Dennis Jamason to clean off the pine needles and make repairs.

Power meters were read, recorded and forwarded.

Submitted by Chuck Grooms,  
RWS FPOA