

February 19, 2015

Roads Water and Sewer Report

Roads: No issues with the roads were reported

Water: I met with Mike and Paul Rose on 2/14 at the plant and tanks. The experiment to place the small tank into the delivery system in an effort to settle the air and particulates seems to have been successful in that there is reduced air in the raw water. This is a continuing effort and the next steps are being considered. It is possible that a tank may need to be located nearer the plant. It was recommended that we obtain a survey to insure we know where our available land use is.

Samples have been tested as required. The boil order remains in effect.

Sewer: The markers to protect and identify our clean-outs and pipes have been placed. During Liberty Energy's installation of a new power pole in our leach field vicinity, some of our access and inspection ports were damaged. Replacement parts have been ordered and will be installed. I will submit a claim to Liberty Energy for reimbursement.

Samples have been taken and submitted for testing as required. Power meters were read and recorded as required.

There is an issue with the trees near the Schoolhouse. Thinning and removal are necessary.

I met with a director of Parks and Rec and was informed that there is funding to improve our kids park. We need to suggest what improvements we would like to see.

Some suggestions are:

- shade
- a low fence to keep dogs from defecating in the area
- a better ground cover
- better access

Submitted by Chuck Grooms,
RWS FPOA